



**FBH-Verteiler 3**

Nr.	HK	mbar	kg/h	EN <sub>v2</sub>
1	001 Kind 2 2	24	49.4	7
2	001 Kind 2 3	28	52.2	7
3	002 Eltern 1	9	25.6	5
4	002 Eltern 2	6	21.7	4
5	004 Ankleide 1	12	31.4	5
6	003 Bad Eltern 2	40	55.5	11
7	003 Bad Eltern 1	29	55.3	7

**FBH-Verteiler 4**

Nr.	HK	mbar	kg/h	EN <sub>v2</sub>
1	001 Kind 2 1	36	57.4	11
2	007 Bad Kinder 2	32	53.4	8
3	007 Bad Kinder 1	12	39.5	5
4	005 Flur 1	15	34.9	5
5	006 Kind 1 1	13	36.7	5
6	006 Kind 1 2	21	44	6
7	006 Kind 1 3	29	49.5	7

<b>Planungsbüro Leisner</b>		33428 Harsewinkel, Brucknerweg 1a	
		Tel. 05247 / 3435 Fax: 05247 / 10951	
Bauvorhaben <b>Neubau eines Wohnhauses</b>			
Bauherr <b>Mustermann</b>			
<b>1. Obergeschoß</b>		Heizungsanlage	
Datum: 01.07.2013		M 1:50	